

**Government of Andhra Pradesh**  
**A.P. State Disaster Response and Fire Services Department**

**Periodical Renewal Fire Certificate**

From:  
Regional Fire Officer  
Zone-4,Kurnool  
Andhra Pradesh.

To:  
The District Educational Officer, Kurnool,

**File No: 30434/KRN/RFO/2026, Date:04/03/2026**  
**Occupancy NoC RC Number: 155/MSB/SR/KNL/2016**

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **M/s. Sri Vidya Nivas (Montessori E.M. High School), represented by Management, D.No.1-30, Sy.No.242/1,2 380 & 381, Panchalingala Gram Panchayath, Kurnool Mandal, Kurnool District** - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
  2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
  3. This Office NOC for Occupancy Rc No. 155/MSB/SR/KNL/2016, Dt.08/02/2017
  4. Renewal NOC For Occupancy 155/MSB/SR/KNL/2016, Dt.02/03/2021
  5. Online Application for Renewal NOC of Management, D.No.1-30, Sy.No.242/1,2 380 & 381, Panchalingala Gram Panchayath, Kurnool Mandal, Kurnool District - Inspection report called for Regarding.
  6. Online Inspection Report submitted by Officers of this Department on 02-03-2026.

-- x --

The Management of M/s. Sri Vidya Nivas (Montessori E.M. High School), represented by Management, D.No.1-30, Sy.No.242/1,2 380 & 381, Panchalingala Gram Panchayath, Kurnool Mandal, Kurnool District has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.252500/- vide challan No. 91375481982025, Dated 23/02/2026 at CFMS, Online.

**Educational Block & Hostel Block**

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **Management D.No.1-30, Sy.No.242/1,2 380 & 381, Panchalingala Gram Panchayath, Kurnool Mandal, Kurnool District**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 27/02/2026 to 26/02/2031.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
91375481982025	2026-02-23	252500

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

- i) This Renewal NOC is issued from Fire Safety Point of view only basing on recommendation of the inspection Committee. It doesn't confer proprietary or ownership rights. If any deviations are noticed post-issuance, this NOC is liable for cancellation at any time.
- ii) The management must maintain fire safety measures and installations in good working condition. Responsibility for firefighting equipment maintenance lies with the management, as verified by the committee during inspection.

**"UNITE TO IGNITE, A FIRE SAFE INDIA"**

**"అగ్ని సురక్షిత భారతదేశానికీ ఐక్యమవ్వండి"**



Your Sincerely,

*[Signature]*  
Regional Fire Officer  
Zone-4, Kurnool  
Andhra Pradesh  
*[Signature]*

***In case of emergency, please call 101 or 08518-255101 or 9963737924***

Copy to Management, M/s. Sri Vidya Nivas (Montessori E.M. High School), D.No.1-30, Sy.No.242/1,2 380 & 381, Panchalingala Gram Panchayath, Kurnool Mandal, Kurnool District

Copy to Chief Office for Record Purpose

Copy to District Fire Officer Concerned

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned